



Certificate number

DE/7535

CERTIFICATE OF TYPE EXAMINATION

Referring to the Test and Classification Reports
 nn. 0182\DC\REA\23, 0182\DC\REA\23_2, 0182\DC\REA\23_3 dated 22/02/2023

we declare that the Manufacturer

IGEPA GROUP GmbH & Co. KG
Heidenkamsweg 74-76 - 20097 HAMBURG - GERMANY

has requested on the specimen sampled by himself and named

Decorative wall covering **Mod. MasterGuard Premium+**

the type testing according to EN 15102:2007+A1:2011 in compliance with the points required by the Manufacturer himself and listed in Annex A of this certificate, according to the System of assessment and verification of constancy of performance 3 (three) - Annex V of the Regulation (EU) n. 305/2011.

The results of the tests on the sample are reported in the Annex A

22/05/2024

First issue

Renewal

Latest issue

21/05/2029

Expiry

Carlo Dassi
 B. A. Certification

pag. 1 / 2

GQ002 REV.00

CERTIFICATE OF TYPE EXAMINATION - Annex A**Decorative wall covering
Mod. MasterGuard Premium+**

According to the type testing performed and the documents of the Technical File deposited at CSI S.p.A., the results are:

Product characteristics:	
Description	Self-adhesive PVC film
Weight per area unit	130 g/m ²
Thickness	0,1 mm
Performances:	
4.1 Reaction to fire	class B-s1, d0
End use	glued on non combustible substrate

22/05/2024

First issue

Renewal

Latest issue

21/05/2029

Expiry