



CE-CERTIFICATE

CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw1220_2023

According to reports N° 23.01209.01 dated on 31/03/23 , we confirm that the below mentioned item was tested at CENTEXBEL, Notified body ≠0493, with reference to EN-ISO 11952-2 (2020): Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test .

The item shows

EU fire classification: E

Provided that it is properly applied.

The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2019: Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

Sample: BEElite 2D and 3D
Company: BEElite nv
Avenue A. Franck 5
7700 Mouscron
Belgium

Certificate No. jw1220_2023 is valid until 30/03/2028
Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 3/04/2023

Inge De Witte, PhD
Certification Manager

A handwritten signature in black ink, appearing to read 'Inge De Witte', written over a horizontal line.